

WHITE MARSH
ENVIRONMENTAL SYSTEMS, INC.
A Middlesex Water Company Affiliate

July 12, 2018

Mr. Darrin Gordon
General Manager
Lewes Board of Public Works
107 Franklin Avenue
Lewes, DE 19958

Subject: Monthly Report, June 2018

Attached is a summary of the Operations and Maintenance activities at the Board's lift stations and wastewater treatment plant for the month of June. Please direct any questions to my attention. Thank you.

Sincerely,



Mike Evans
District Manager
Tidewater Utilities, Inc.

I. Effluent Quality and Compliance

- Discharge Monitoring Report submitted to DNREC with 100% compliance for the month.

June 2018 Effluent Testing

Sample Data	Total Nitrogen	Total Phosphorus	BOD	TSS	Enterococcus
Average:	1.80 mg/L	0.36 mg/L	<2.40 mg/L	<0.63 mg/L	<1.0 Col.
Maximum:	N/A	N/A	<2.40 mg/L	<1.00 mg/L	<1.0 Col.
Permit Limit:	8 mg /L average	2 mg /L average	15 mg/L average 23 mg/L MAX	15 mg/L average 23 mg/l MAX	10 Col. average

Maximum daily flow 0.8566 MGD
Monthly average flow 0.7215 MGD

II. Activities

STATION MAINTENANCE PERFORMED

- Station #17 failed pump removed, rebuilt, and reinstalled. Replaced a failed low level float. A replacement spare pump was ordered.
- Hornkill Rd. station #11 overflow. Station was pumped down by hand, lime was spread on a puddle in front yard. Replaced three level control floats and found the station control cabinet was not properly grounded. Tidewater Maintenance grounded the cabinet for safety and added protection for equipment. Tidewater electricians notified BPW Electric Department that meter pan is rotted out and requested that it be replaced.
- Harry Caswell crew along with several BPW workers pumped down station #8 to replace an underground valve that would not fully close. Preparation for the magnetic flow meter installation project by Tidewater is underway.
- Lift stations 1,2,3,10,11,14,19 inspected by Tidewater electricians.

MAINTENANCE PERFORMED

- Installed new gaskets into train #2 permeate pump.
- Continued permeate low flow train shut downs.
- Sludge hauler on 6/6- 6/12 and 6/ 20- 6/21 totaling 130.99 tons removed for June.
- Grit auger in headworks deteriorating. Maintenance Informed.
- Maintenance removed the digester membrane's blower and motor and sent them out to be refurbished. Maintenance installed a rebuilt motor and blower. Blower unit in service.
- Membrane blower C went out of service due failed motor.
- Secondary RAS (return activated sludge) pump faulted due to a bad VFD. The pump was temporarily rewired to train 4's Primary RAS pump VFD. Maintenance is searching for a replacement VFD.
- Installed a reconditioned motor on train #2.
- Headworks E.Q. pump VFD #2 went down leaving pumps #1 and #3 to move the town's wastewater through the plant. Maintenance and HIE worked together on diagnosing the VFD fault. The VFD is back on line.
- Maintenance in to install a new mixer in bioreactor 1A.
- Repairs made to the screening/dewatering system.

SAFETY INFORMATION

No work place injuries.

PPE inspected.

Eyewash and fire extinguisher inspections conducted.

Annual Fire Extinguisher certification scheduled for July 20th 2018

**Caustic lines in chemical building, process building, and in the retaining area of process building have deteriorated. Crystallization is occurring causing a safety hazard. Leaking Caustic is seeping through the retaining wall in the process building as well.

ADDITIONAL INFORMATION

Tidewater in to evaluate hydrogen sulfide in the Gorman Pump E. U. pump cabinets.

Tidewater in to evaluate the bioreactors for the air diffuser replacement project.

The Lewes WWTP produces near drinking water quality effluent.

LEWES WWTF
NUTRIENT OFFSET REPORT

MONTH	Days	Average Monthly Flow	Monthly TN mg/L	Total Monthly TN Discharged	TN Based 16.9 lbs Manure Offset Required	Poultry Manure Relocated	Poultry Manure Offset Balance	Monthly Average TP	Total Monthly TP Discharged	TP Based 285 lbs Manure Offset Required
		MGD	mg/L	Lbs.	Lbs.	Tons	Lbs.	mg/L	Lbs.	Lbs.
Carry Over										
January	31	0.5796	7.81	17,033	19778.52		130,493.68	0.36	53.95	15374.59
February	28	0.6619	4.68	12,444	7040.31	1554.93	3,201,919.16	0.43	65.46	18655.99
March	31	0.7362	4.73	900.29	15,14.98		3,186,704.18	0.25	47.58	13561.52
April	30	0.6802	2.40	408.47	402.75		3,141,596.37	0.93	158.27	45107.81
May	31	0.7910	1.47	300.62	5087.2		3,111,288.71	0.52	106.34	30307.66
June	30	0.7215	1.80	324.93	514.47		3,092,767.43	0.36	64.99	18521.28
July	31			0.00	0.00		3,092,767.43		0.00	0.00
August	31			0.00	0.00		3,092,767.43		0.00	0.00
September	30			0.00	0.00		3,092,767.43		0.00	0.00
October	31			0.00	0.00		3,092,767.43		0.00	0.00
November	30			0.00	0.00		3,092,767.43		0.00	0.00
December	31			0.00	0.00		3,092,767.43		0.00	0.00
Year Balance							3,092,767.43			

Comments: Effective July 1, 2018 we will be using the new required Manure offset lbs. of 16.9 lbs. for TN and 285 lbs. for TP as set by DNR/REC. This sheet has been recalculated to reflect these calculations back to January 1, 2018.

Paula Todd Smith
 Authorized Signatory

7/13/18
 DATE

Preliminary Report



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (City, State, County, City Name, Location if different):
 City of Lewes - Boal - 116 American Legion Road, Lewes, DE 19958 US

NAME: City of Lewes - Boal
 ADDRESS: 116 American Legion Road, Lewes, DE 19958 US
 FACILITY: Howard Seymour Water Reclamation Plant

DE0021512
 PERMIT NUMBER

001
 DISCHARGE NUMBER

REPORT DESIGNATOR: A
 DATA ENTRY COMPLETE: 7/11/2018
 REPORT SUBMITTED BY: gloria.leitchick@state.ec.ny.us.com

LOCATION: 116 American Legion Road, Lewes, DE 19958 US

FROM: 2018 06 01

TO: 2018 06 30

STATUS OF SUBMISSION: Submitted for Signature

#	PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION			UNITS	NO. OF ANALYSIS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
			AVERAGE	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	MINIMUM				
1/1	Flow	Gross Effluent (50050)	215	0.8566				Mill Gal/Day	0	99/99	Recorder	
1/2	Dissolved oxygen (DO)	Gross Effluent (00300)	Monitoring Required	No Limit Monitoring Req'd	3.6	No Monitoring Required	No Monitoring Required	mg/l	0	99/99	Measured	
1/3	pH	Gross Effluent (00400)	Monitoring Required	No Monitoring Required	7.2	No Monitoring Required	No Limit Monitoring Req'd	Std pH Units	0	01/01	Grab	
1/4	Enterococcus	Gross Effluent (31639)	No Monitoring Required	No Monitoring Required	6	No Monitoring Required	No Monitoring Required	Std pH Units	0	01/01	Grab	
1/5	BOD5	Gross Effluent (00310)	<14.1	<16.34	<2.4	<2.4	<2.4	mg/l	0	01/07	Comp 8	
1/6	TSS	Gross Effluent (00530)	<3.61	<5.38	<0.63	<1	<1	mg/l	0	01/07	Comp 8	
1/7	Total Nitrogen	Gross Effluent (00600)	10.83	12.26	1.8	1.8	1.8	mg/l	0	01/30	Comp 8	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER: JATTACH DIGITAL SIGNATURE RECEIPT FROM CROWBERRY

TYPED OR PRINTED: SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

DATE: YEAR MO DAY



NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (If the Facility Name/Location is different):

NAME: City of Lewes - Board of Public Works LPWV
ADDRESS: 116 American Legion Road, Lewes, DE 19958 US
FACILITY: Howard Seymour Wastewater Treatment Plant

DE0021512

PERMIT NUMBER

MONITORING PERIOD

001

DISCHARGE NUMBER

REPORT COMPLETE

A

REPORT DESIGNATOR

DATA ENTRY COMPLETE

7/11/2018

gloria.letchick@stservic
es.com

Submitted for Signature

FROM 2018 06 01

TO 2018 06 30

STATUS OF SUBMISSION

PARAMETER	NO. OF SAMPLE MEASUREMENTS	QUANTITY OR LOADING		QUALITY OR CONCENTRATION		UNITS	NO. OF ANALYSIS	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	AVERAGE	MAXIMUM				
Phosphorus, Total	2/1	0.11	2.45	0.36	0.36	mg/l	0	01/30	Comp 8
Gross Effluent (00665)	PERMIT REQUIREMENT	25	No Limit	2	No Limit	mg/l	-	01/30	Comp 8

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments in e)

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY OBTAIN AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY KNOWLEDGE AND BELIEF, TRUE ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.

ATTACH DIGITAL SIGNATURE RECEIPT FROM (NAME AND ADDRESS)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

YEAR

MO

DAY

Submission Receipt

Copy of Record: 37764 Confirmation ID: r201871337764

Site: Howard Seymour Water Reclamation
Plant

Site ID: DE0021512

Submission: Discharge Monitoring Report for DE0021512 Howard Seymour
Water Reclamation Plant Outfall: 001, June, 2018

File Name: 20186-1428-60660265

File Type: .pdf

Report: DMR

Status: Signed

Hash of Data Document:

054036c4a164fc354e06145e9a3b3fd4eb38b0ab91734e5b0519aef889b365be

Data Entry Completed: 7/11/2018
2:26 PM

By: Gloria Lefchick
(gloria.lefchick@stservices.com)

E-Mail of Submitter:
Gloria.Lefchick@STServices.com

From: 64.235.154.12

Signed: 7/13/2018 3:33 PM

By: Ronald Griffith
(rgriffith@tuiwater.com)

E-Mail of Signator: rgriffith@tuiwater.com

From: 203.117.234.202

Token Used When Signed: KQdNrPabpFEJJF2ta+O7K4W cSV8y JyoRp+9+Dsk=