

Electric Outages Lewes BPW

| Month | Date | Circuit | Customers Interrupted | Duration | Cause | Percent System Reliability |
|---------------|------------|---------|-----------------------|----------|-------------------------------|----------------------------|
| January 2018 | 1/12/2018 | 3 | 32 | 180 | Equipment Damage | 99.78726% |
| | 1/20/2018 | 2 | 5 | 30 | Squirrel | |
| | 1/20/2018 | 1 | 1 | 30 | Squirrel | |
| February 2018 | No outages | | | | | 100% |
| March 2018 | 3/6/2018 | 3 | 647 | 150 | Equipment Damage | 96.53075% |
| April 2018 | 4/15/18 | 4 | 630 | 50,400 | Tree | 72.31603% |
| | 4/18/18 | | 3717 | 698,796 | Utility Maintenance & Repairs | |
| | 4/22/18 | 1 | 1 | 45 | Squirrel | |
| | 4/23/18 | 4 | 1 | 20 | Squirrel | |
| May 2018 | 5/12/18 | 3 | 1 | 45 | Equipment worn | 99.99839% |
| June 2018 | No outages | | | | | 100% |
| July 2018 | 7/28/18 | 2 | 5 | 60 | Bird | 99.97213% |
| | 7/29/18 | 2 | 8 | 60 | Squirrel | |
| August 2018 | 8/5/18 | 1 | 4 | 45 | Squirrel | 99.98497% |
| | 8/10/18 | 1 | 1 | 120 | Equipment Damage | |
| | 8/11/18 | 4 | 1 | 120 | Equipment Damage | |
| September | 9/8/18 | 1 | 4 | 60 | Equipment worn out | 99.99191% |
| | 9/8/18 | 2 | 1 | 60 | Equipment worn out | |
| | 9/26/18 | 2 | 2 | 15 | Equipment worn out | |