

| <b>PUMP STATION</b> |    | <b>196</b>     |                  |
|---------------------|----|----------------|------------------|
| <b>Jan-21</b>       |    | <b>PS 196</b>  |                  |
|                     |    | <b>METER</b>   | <b>24 HOUR</b>   |
|                     |    | <b>READING</b> | <b>FLOW</b>      |
| FRI                 | 1  | 12302770       | 0.419860         |
| SAT                 | 2  | 12722630       | 0.403940         |
| SUN                 | 3  | 13126570       | 0.422550         |
| MON                 | 4  | 13549120       | 0.404230         |
| TUE                 | 5  | 13953350       | 0.379340         |
| WED                 | 6  | 14332690       | 0.374530         |
| THUR                | 7  | 14707220       | 0.374590         |
| FRI                 | 8  | 15081810       | 0.389480         |
| SAT                 | 9  | 15471290       | 0.383190         |
| SUN                 | 10 | 15854480       | 0.416430         |
| MON                 | 11 | 16270910       | 0.340910         |
| TUE                 | 12 | 16611820       | 0.350890         |
| WED                 | 13 | 16962710       | 0.368600         |
| THUR                | 14 | 17331310       | 0.375770         |
| FRI                 | 15 | 17707080       | 0.339200         |
| SAT                 | 16 | 18046280       | 0.315330         |
| SUN                 | 17 | 18361610       | 0.305830         |
| MON                 | 18 | 18667440       | 0.326220         |
| TUE                 | 19 | 18993660       | 0.354960         |
| WED                 | 20 | 19348620       | 0.344550         |
| THUR                | 21 | 19693170       | 0.332490         |
| FRI                 | 22 | 20025660       | 0.351090         |
| SAT                 | 23 | 20376750       | 0.374540         |
| SUN                 | 24 | 20751290       | 0.383770         |
| MON                 | 25 | 21135060       | 0.357730         |
| TUE                 | 26 | 21492790       | 0.344830         |
| WED                 | 27 | 21837620       | 0.331140         |
| THUR                | 28 | 22168760       | 0.347030         |
| FRI                 | 29 | 22515790       | 0.346340         |
| SAT                 | 30 | 22862130       | 0.357980         |
| SUN                 | 31 | 23220110       | 0.365880         |
|                     |    | 23585990       |                  |
| <b>TOTAL</b>        |    |                | <b>11.283220</b> |
| <b>COUNT</b>        |    |                | <b>31</b>        |
| <b>AVERAGE</b>      |    |                | <b>0.363975</b>  |
| <b>MINIMUM</b>      |    |                | <b>0.305830</b>  |
| <b>MAXIMUM</b>      |    |                | <b>0.422550</b>  |

# LEWES BPW WWTP Biweekly InSight Report

**Date:** 1/27/2021

From: Erin Horocholyn - Suez Water Technologies & Solutions  
 To: Darrin Gordon, Austin Calaman, Inframark  
 cc: Matt Stapleford - Suez Water Technologies & Solutions

## System Equipment

4 × ZW trains, each train consists of 4 - 500D cassettes, 120 modules x 370 sq. ft. per train (surface area 44,400 sq. ft. per train)

Replacement membranes installed Q1 2020 on trains UF3 and UF4





## Cleaning Strategy

Recovery cleaning - 2 NaOCl @ 2000 ppm dose/1000 ppm soak per year, 1 Citric acid @ 2000 ppm per year

Maintenance cleaning - 1 NaOCl per week @ 200 ppm, 1 Citric acid per week @ 2000 ppm

## KPI Dashboard – Avg values through reporting period


■ Action Required  
■ Caution  
■ No Limits  
■ Normal



## Plant Summary

Overall, trains UF1 – UF3 operated well, with good TMPs and permeabilities. UF4 is being pulled for cleaning.

- Daily permeate production averaged 0.64 MGD. Flow peaked on Jan 13 at 0.72 MGD. Train UF4 has been mainly off during this report. Train UF2 was taken out of full production from Jan 18 – 25, so flux increased on UF1 and UF3 which handled the plant load during this time
- Flux BBP averages ranged from 9.01 – 9.44 gfd for all trains
- Average TMP BBP was good on trains UF1, UF2, and UF3, averaging 0.87, 0.74, and 0.46 psi respectively. Train UF4 averaged 5.17 psi, up from the previous average of 1.93 psi
- TC permeability BBP was excellent on UF1, UF2, and UF3, averaging 13.23, 14.33, and 24.91 gfd/psi respectively. Train UF4 averaged 2.99 gfd/psi, down from the previous average of 5.67 gfd/psi
- UF4 has had high TMP BBP reaching TMP control (TMP > ~7.0 psi) since Dec 16, 2020. On Jan 26, a module from UF4 was pulled, and the LEAP air diffusers were found to be clogged with sludge. The other modules will be pulled, and their diffusers and center channel cleaned. After, a recovery clean will be run. After the RC, the train will be aerated for 24 hours in clean permeate water to dislodge solids. Then, the modules will be pulled and manually cleaned to remove any remaining sludge. There is also separation of values between TMP before and after BP, indicating in-cycle fouling. The plot below shows daily median averages, and skips days UF4 wasn't in Production



- Permeate turbidity ABP averaged 0.05, 0.25, 0.10, and 0.81 NTU on UF1, UF2, UF3, and UF4
- UF1, UF2, and UF4 had 2 hypo and 2 citric MCs, while UF3 had 3 hypo and 1 citric MC in this report


### Acronyms:

TC = temperature corrected, BBP = before backpulse, ABP = after backpulse, DBP = during backpulse, RC = recovery clean, MC = maintenance clean, TMP = trans membrane pressure




### TC Permeability Trends By Train


■ TCPermeabilityAfterBP  
■ TCPermeabilityBeforeBP  
■ TCPermeabilityDuringBP



■ TCPermeabilityAfterBP  
■ TCPermeabilityBeforeBP  
■ TCPermeabilityDuringBP




■ TCPermeabilityAfterBP  
■ TCPermeabilityBeforeBP  
■ TCPermeabilityDuringBP







■ TCPermeabilityAfterBP  
■ TCPermeabilityBeforeBP  
■ TCPermeabilityDuringBP




### Permeate Turbidity Trend




### Before BPTMP Trend



### Before BP Flux Trend




### Daily Permeate Flow



Average Daily permeate flow from 1/13/2021 to 1/26/2021 is 642.5k gal with a maximum daily flow of 723.9k gal.

# Data Over Time




Date ( 11/1/2020 to 1/31/2021 )

▲ PS4 Calculate ■ PS8 Calculate ▼ Sussex County Flows ◆ Precipitation

Flows

PS4,8 +County

# Data Over Time




Date ( 11/1/2020 to 1/31/2021 )

- ▲ PS5 Total Pumped
- PS6 Total Pumped
- ▼ PS1 Total Pumped
- PS2 Total Pumped
- ◆ Precipitation




# Data Over Time



Date ( 11/1/2020 to 1/31/2021 )

▲ PS11 Total Pumped    ■ PS12 Total Pumped    ▼ PS3 Total Pumped    ● PS14 Total Pumped    + PS13 Total Pumped    ◆ Precipitation


# Data Over Time



Date ( 11/1/2020 to 1/31/2021 )

- ▲ PS17 Total Pumped
- PS17B Total Pumped
- ▼ PS18 Total Pumped
- PS16 Total Pumped
- ◆ Precipitation


# Data Over Time



Date ( 11/1/2020 to 1/31/2021 )

- ▲ PS74 Total Pumped
- PS83 Total Pumped
- ▼ PS 15 Total Pumped
- PS7 Total Pumped
- ◆ Precipitation

# Data Over Time



**Date ( 11/1/2020 to 1/31/2021 )**  
▲ PS9 Total Pumped    ■ PS10 Total Pumped    ▼ PS19 Total Pumped    ● PS32 Total Pumped    ◆ Precipitation



### Asset Summary

| KPI Parameters                 | Value/Change | UF1      | UF2       | UF3      | UF4       |
|--------------------------------|--------------|----------|-----------|----------|-----------|
| FluxBeforeBP gfd               | Value        | 9.44     | 9.04      | 9.24     | 9.01      |
|                                | Change       | 5.02 %   | -7.53 %   | 2.45 %   | -1.68 %   |
| FluxDuringBP gfd               | Value        | 18.86    | 18.49     | 18.54    | 18.79     |
|                                | Change       | -0.24 %  | -0.53 %   | -0.36 %  | 0.14 %    |
| PermeateTurbidityAfterBP NTU   | Value        | 0.05     | 0.25      | 0.10     | 0.81      |
|                                | Change       | 15.99 %  | -2.75 %   | 19.08 %  | 83.94 %   |
| TCPermeabilityBeforeBP gfd/psi | Value        | 13.23    | 14.33     | 24.91    | 2.99      |
|                                | Change       | -13.33 % | -2.21 %   | 1.67 %   | -89.46 %  |
| TMPBeforeBP psi                | Value        | 0.87     | 0.74      | 0.46     | 5.17      |
|                                | Change       | 18.18 %  | -5.88 %   | 2.78 %   | 62.57 %   |
| TotalPermeateFlowDaily gal     | Value        | 273.05k  | 140.64k   | 221.59k  | 8.00k     |
|                                | Change       | 0.96 %   | -119.57 % | -18.53 % | -120.74 % |

### Plant Summary

| KPI Parameters             | Value/Change | UF Plant |
|----------------------------|--------------|----------|
| TotalPermeateFlowDaily gal | Value        | 720.25k  |
|                            | Change       | -29.41 % |

Contract Expiry Date : 08/11/2021

For InSight technical assistance please email [insight.src@suez.com](mailto:insight.src@suez.com) or please call technical support at 1 866 271 5425 or 905 469 7723 and follow the prompts, if you require after hours assistance please contact the 24/7 Emergency number provided in your plant documentation. This email is a summary of issues identified during a manual review of InSight data from the time period above. This review is an analysis of data that is logged by InSight and identifies key plant performance issues determined from this data. This data review was not focused on minor data issues but on identifying possible existing and/or upcoming critical operational issues.

This review was prepared by SUEZ Water Technologies & Solutions solely to assist water treatment plant owners and/or operators in analyzing and optimizing plant performance and is not intended to be used or relied upon for regulatory compliance or any other purpose. The content of this review is based in whole or in part on operation data obtained from the plant using InSight software. SUEZ Water Technologies & Solutions makes no representations or warranties as to the accuracy of the plant data utilized in the preparation of this review. SUEZ Water Technologies & Solutions accepts no liability for consequences or actions taken in whole or in part by any person on the basis of this review or its contents