

Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2020	1/31/20	3	50	60	Equipment Damage	99.99823%
February 2020	2/6/20 2/20/20	1 2	1 210	15 170	Squirrel Equipment Damage	99.97747%
March 2020	3/12/20 3/29/20	1 1	1 4	25 60	Squirrel Squirrel	99.99986%
April 2020	4/28/20	1	1	30	Squirrel	99.99998%
May 2020	No outages					100%
June 2020	6/4/20 6/7/20 6/7/20 6/7/20 6/23/20	1 1 1 2 2	5 5 4 3 4	60 60 60 60 30	Bird Squirrel Squirrel Bird Bird	99.99931%
July 2020	7/13/20 7/14/20	1 1	5 11	20 90	Squirrel Equipment Damage	99.99936%
August 2020	8/4/20 8/4/20 8/4/20 8/4/20 8/8/20 8/24/20	1 3 3 3 1 3	3717 3 1 3 9 13	12 105 75 90 120 20	Failure of greater transmission Storm Storm Storm Tree Equipment worn out	99.97276%
September 2020	No outages					100%
October 2020	No outages					100%
November 2020	No outages					100%
December 2020	12/25/2020	1	6	60	Squirrel	99.9979%

TOTAL 2020 reliability = 99.99556%